

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 100

Date: 25/05/2026

It is certified that an inspection team headed by R. S. SHRIRAJ
Assistant Engineer (Name of Officers
with designation) from P.H. Sub. Division Ekangarsarai (Name of
Department/Office) inspected the Sabarmati Gyan Niketan
Gandhi Nagar Telhara Nalanda - 801306 (Name & Address of
the School) on 25/05/2026 and found that the Sabarmati Gyan
Niketan Gandhi Nagar Telhara Nalanda - (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of Six months.

Signature with Seal :

25/05/26

S.D.O

Name

: R. S. Shriraj **PH SUB DIVISION**
NALANDA

Designation

: Assistant Engineer

To

Sabarmati Gyan
Niketan, Gandhi Nagar
Telhara Ekangarsarai, Nalanda.

(Name & Address of the Institution)

Government of Bihar
Public Health Engineering Department
Water Quality Report
Division Name: Public Health Engineering Division, Biharsharif & Hilsa

District Name: Nalanda

Sample Collected by :- Ref no-SBGN/026/MAY-12 DATE-20.5.26 Dhananjay Kumar						Date of Sampling :- 22/05/2026													
Sl. No.	Block	Panchayat	Village	Habitat	Location of Source	Test result													Source of Water
						pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
1	EKANGARSARAI	KESOPUR	GANDHI NAGAR TELHAR	GHANDHI NAGAR TELHAR	SABARMATI GYAN NIKETAN	7.98	0.94	316	210	130	32	12	30	140	0.12	<1.0	10.6	0.534	Tap water
						Desirable Limit	1	-	500		75	30	250	200	1	45	200	1	-
						Permissible Limit* in absence of alternate source	NR	5	-	2000	600	200	100	1000	600	NR	400	1.5	-

Dandho.
25/5/2026
Chemist
Public Health Division, Biharsharif
(Nalanda)